



- NOTES:
1. VENT STACKS AND OTHER PIPES SHOULD HAVE A MINIMUM OF 12 INCHES OF CLEARANCE ON ALL SIDES FROM WALLS, CURBS, AND OTHER PROJECTIONS TO FACILITATE PROPER FLASHING. (SEE TABLE 4.)
 2. TOP LAYER OF INSULATION CAN BE EITHER THERMAL INSULATION OR COVERBOARD INSULATION.

A
08

PLUMBING VENT

PROJECT TITLE :

ROOF RECOVERY

2014

JOB NO.,

DRAWN BY :

CHECKED

SCALE

DATE

8/7/2014

CAD FILE

SHEET

DRAWING NO.

d0008